




Product Service

Attestation of Conformity

No. N8 10 09 64308 010

Holder of Certificate: WOONYOUNG CO., LTD.110-3, Dangjung-Dong
Gunpo-City, Kyunggi-Do 435-831
REPUBLIC OF KOREA**Product: Electronic transformer
(Current Transformers)**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2006/95/EC relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.: CPSA0129469**Date,** 2010-09-28
(James Jeon)

After preparation of the necessary technical documentation as well as the EC conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.

Page 1 of 3



Product Service

Attestation of Conformity

No. N8 10 09 64308 010

Model(s): CS-160, CS-130, CS-104, CS-85,
CS-65, CS-44, CS-65D, CS-44D

Parameters:

Rated primary current:	See attachment
Rated secondary current:	5 or 1 A
Rated frequency:	50/60 Hz
Highest voltage:	1150 V
Accuracy class:	1.0
Burden:	See attachment

Tested according to: EN 60044-1/A2:2003



Attestation of Conformity N8 10 09 64308 010

● Remark:

Parameters: Rated primary current : 100, 150-200, 250-300, 300 A (CS-44)
400, 500-600 A (CS-65)
600-1000 A (CS-85)
1200-2000 A (CS-104)
1200-3000 A (CS-130)
2500-6000 A (CS-160)
200/100, 300/150 A (CS-44D)
400/200, 500/250, 600/300 A (CS-65D)

Burden : 5 or 15, 15, 40 VA (CS-44)
15 or 40 VA (CS-65, CS-85, CS-104,
CS-130, CS-160)
5, 5 or 15 VA (CS-44D)
15, 40, 15 or 40 VA (CS-65D)