



Product Service

# EC-Attestation of Conformity

No. N8 07 08 64308 001

**Holder of Certificate:** **WOONYOUNG CO., LTD.**

110-3, Dangjung-Dong  
 Gunpo-City, Kyunggi-Do 435-831  
 REPUBLIC OF KOREA

**Product:** **Transformer, isolation  
 (Noise Cut Transformer)**

**Model(s):** **WYNC22-\***  
**(WYNC22-300L, WYNC22-500L, WYNC22-1kL)**  
**Remark: The suffix \* can be 300L, 500L or 1kL.**

<b>Parameters:</b>	Rated input voltage:	220 V a.c.
	Rated input frequency:	50/60 Hz
	Rated input:	Max. 5 A
	Rated output:	220 V a.c., Max. 1 KVA
	Protection class:	I
	Thermal classification:	H
	Degree of protection against ingress of liquids:	IP00

**Tested according to:** EN 61558-2-4:1997  
 EN 61558-1/A11:2003

This EC-Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2006/95/EC relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

**Test report no.:** CPSA0110737

**Date,** 2007-08-24



**CE** After preparation of the necessary technical documentation as well as the conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.