



Product Service

Attestation of Conformity

No. N8A 17 01 64308 037

Holder of Certificate: WOONYOUNG CO., LTD.2122-20, Cheonan-daero, Seonghwan-eup, Seobuk-gu
Cheonan-si, Chungcheongnam-do, 31022
REPUBLIC OF KOREA**Product:** Transformer, isolation
(ISOLATING TRANSFORMER)**Model(s):** WY3P-50K.PR

Parameters:	Rated input Voltage:	208 Va.c., 3PH
	Rated frequency:	50/60 Hz
	Rated output voltage:	400 Va.c.
	Rated output current:	72.1 A
	Rated output power:	50 kVA
	Thermal classification:	H
	Protection Class :	I
	Degree of protection against ingress of liquids:	IP00

Tested according to: EN 61558-2-4:2009
EN 61558-1:2005/A1:2009

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.: CPSA01005217**Date,** 2017-01-13

(Hyuk-Jun Kwon)



After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.

Page 1 of 1