



Product Service

EC-Attestation of Conformity

No. N8 08 05 64308 005

Holder of Certificate: **WOONYOUNG CO., LTD.**

110-3, Dangjung-Dong
 Gunpo-City, Kyunggi-Do 435-831
 REPUBLIC OF KOREA

Product: **Safety-, control- and regulator equipment
 (Thyristor Power Regulator Unit)**

This EC-Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2006/95/EC relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.: CPSA0114468



Date, 2008-05-23



After preparation of the necessary technical documentation as well as the conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.



Product Service

EC-Attestation of Conformity
No. N8 08 05 64308 005

Model(s): WYU-DH40TM

Parameters:

Rated input voltage:	380-440 V a.c.
Rated frequency:	50/60 Hz
Rated input current:	40 A
Rated output:	380-440 V a.c.
Protection class:	I
Degree of protection:	IP20

Tested according to: EN 50178:1997