



Product Service

Attestation of Conformity

No. N8 10 11 64308 012

Holder of Certificate: WOONYOUNG CO., LTD.

110-3, Dangjung-Dong
 Gunpo-City, Kyunggi-Do 435-831
 REPUBLIC OF KOREA

**Product: Electronic transformer
 (Voltage Transformers)**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2006/95/EC relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.: CPSA0129449


 (James Jeon)

Date, 2010-11-05



CE After preparation of the necessary technical documentation as well as the EC conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.



Product Service

Attestation of Conformity**No. N8 10 11 64308 012****Model(s):** EVT-100F, EVT-50F, VT-100F, VT-50F**Parameters:**

Rated primary voltage:	See attachment
Rated secondary voltage:	See attachment
Rated frequency:	50/60 Hz
Max. Voltage:	1150 V
Accuracy class:	1.0
Burden:	100 VA (EVT-100F, VT-100F) 50 VA (EVT-50F, VT-50F)

**Tested
according to:**

EN 60044-2/A2:2003



Product Service

Attestation of Conformity N8 10 09 64308 012

● Remark:

Parameters: Rated primary voltage: 110-600 V~ (VT-50F, VT-100F),
110/√3-480/√3 V~ (EVT-100F, EVT-50F)

Rated secondary voltage: 110 or 220 V~ (VT-50F, VT-100F),
110/√3 or 190/√3 V~ (EVT-100F, EVT-50F)