



Product Service

# Attestation of Conformity

No. N8 10 09 64308 011

**Holder of Certificate: WOONYOUNG CO., LTD.**

110-3, Dangjung-Dong  
 Gunpo-City, Kyunggi-Do 435-831  
 REPUBLIC OF KOREA

**Product: Electronic transformer  
 (Current Transformers)**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2006/95/EC relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

**Test report no.:** CPSA0129489



**Date,** 2010-09-28 ( James Jeon )

**CE** After preparation of the necessary technical documentation as well as the EC conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.



Product Service

**Attestation of Conformity**  
**No. N8 10 09 64308 011**

**Model(s):** CR-60, CR-40, CR-30, CR-15

**Parameters:**

Rated primary current:	50-200 A (CR-15) 50-300 A (CR-30) 240-600 A (CR-40) 400-1500 A (CR-60)
Rated secondary current:	5 or 1 A
Rated frequency:	50/60 Hz
Highest voltage:	1150 V
Accuracy class:	1.0
Burden:	2.5-5 VA (CR-15) 2.5-15 VA (CR-30) 5-40 VA (CR-40, CR-60)

**Tested according to:** EN 60044-1/A2:2003