




Attestation of Conformity

according to Low Voltage directive (2014/35/EU)

Certificate No.
CA20P3093

<i>Owner of Certificate</i>	WOONYOUNG Co., Ltd. 2122-20, Cheonan-daero, Seonghwan-eup, Seobuk-gu, Cheonan-si, Chungcheongnam-do, 31022, Korea
<i>Manufacturer</i>	WOONYOUNG Co., Ltd. 2122-20, Cheonan-daero, Seonghwan-eup, Seobuk-gu, Cheonan-si, Chungcheongnam-do, 31022, Korea
<i>Trade Mark</i>	
<i>Product</i>	NOISE FILTER
<i>Type/Model</i>	WYFTH300T2A, WYFTH400T2A, WYFTH500T2A, WYFTH600T2A, WYFTH800T2A, WYFTH1000T2A, WYFTH1200T2A
<i>Reference Document</i>	Test report (No. SR-20-0388, rev.0 dated on 16-09-2020) According to EN 60939-1:2010 & EN 60939-2:2005

The product described above complies with the requirements of the Low Voltage Directive (2014/35/EU). The details about the product conformity and applied standards are mentioned in the test report referenced above. This certificate is subject to Kiwa Korea Ltd. regulations and it is valid only for the above mentioned electrical product. This Certificate, different from an EC Certificate, counts as Attestation of conformity to be used by first part.

<i>Issue date</i>	15-10-2020
<i>Last revised date</i>	N/A
<i>Expiry date</i>	N/A
<i>Revision</i>	0

Kiwa Korea Lead Auditor

Kiwa Korea General Manager

Kiwa Korea Ltd.

411, SJ Technoville, 278, Beotkkot-ro, Gumcheon-gu, Seoul, Korea
Tel: +82.2.3397.0101, Fax :+ 82.2.3397.0105
E-mail: info@kiwa.kr, Web: www.kiwa.kr



The CE marking may be used if all relevant and effective EC directives are complied with.



Attestation of Conformity
 according to Low Voltage directive (2014/35/EU)

Certificate No.
CA20P3093

※ Model difference table

Model name	Power rating	Fixing type
WYFTH300T2A	500 V 3~ 50/60 Hz, 300 A	Bolt
WYFTH400T2A	500 V 3~ 50/60 Hz, 400 A	Bolt
WYFTH500T2A	500 V 3~ 50/60 Hz, 500 A	Bolt
WYFTH600T2A	500 V 3~ 50/60 Hz, 600 A	Bolt
WYFTH800T2A	500 V 3~ 50/60 Hz, 800 A	Bolt
WYFTH1000T2A	500 V 3~ 50/60 Hz, 1 000 A	Bolt
WYFTH1200T2A	500 V 3~ 50/60 Hz, 1 200 A	Bolt

※ These noise filters employ Class B (130 °C) insulation system.

※ These noise filters were suitable for use in a maximum air ambient of 50 °C

Kiwa Korea Ltd.

411, SJ Technoville, 278, Beotkkot-ro, Gumcheon-gu, Seoul, Korea

Tel: +82.2.3397.0101, Fax :+ 82.2.3397.0105

E-mail: info@kiwa.kr, Web: www.kiwa.kr



The CE marking may be used if all relevant and effective EC directives are complied with.